

13.13 SEPARATE CONNECTION REQUIRED. Each principal building served by the Utility shall have a separate and independent water service from the public main.